



ADDENDUM NO. 2 - OUTLINE AND SUMMARY INFORMATION

Project Name: Fieldhouse 159TR UIT Racks to Generator
Location: Montana State University - Bozeman
Owner: State of Montana, MSU - Bozeman
Plew Building 6th and Grant, PO Box 172760
Bozeman, Montana 59717-2760

PPA No.: 23-0839
Date: 10/15/25

To: *All Plan Holders of Record*

*The Plans and Specification prepared by **TD&H Engineering** dated **September 15, 2025** shall be clarified and added as follows. The bidder proposes to perform all the following clarifications or changes. It is understood that the Base Bid shall include any modification of Work or Additional Work that may be required by reason of the following change or clarifications.*

The Bidders are to acknowledge the receipt of this Addendum by inserting its number and date into their Bid Forms. Failure to acknowledge may subject the Bidder to disqualification and rejection of the bid. This Addendum forms part of the Contract Documents as if bound therein and modifies them as follows:

1. AMENDMENTS TO THE PROJECT MANUAL

- a. Permit Notice – Review and permitting will now be conducted through the State of Montana rather than the City of Bozeman. The project manual will be updated to reflect this on a future addendum. The owner shall pay for review fees and the contractor shall pay for all permit fees.

2. AMENDMENTS TO THE DRAWINGS

- a. SHEET E2.0, Specific sheet note 1 – **ADD:** “All conduits installed in hallway shall be painted white to match existing conduits where visible”. Conduit in mechanical room or above lay-in ceiling does not need painting.”
- b. SHEET E2.0, Specific sheet note 5 – **CLARIFICATION:** The contractor shall be responsible for all grass repair (seeding) as related to trenching of new gas service and underground conduit installation. No irrigation lines are anticipated in this work area.
- c. SHEET E2.0, Specific sheet note 7 – **CLARIFICATION:** In addition to the underground electrical secondary lines from the pad mounted transformer to the building, there is also an underground lighting circuit in this area. The contractor shall hand dig when above these existing utilities and install new conduits above them.

3. AMENDMENTS TO EQUIPMENT INFORMATION

- a. N/A

4. PRE-BID MEETING INFORMATION AND CLARIFICATIONS

- a. All Northwestern Energy fees in relation to the gas service will be paid directly by MSU. The contractor shall be responsible for assisting in the coordination of the new gas service installation.
- b. The final addendum will go out on October 21st – all contractor questions must be sent to Engineer prior to this date.

5. PRIOR APPROVALS

- a. N/A

6. ATTACHMENTS

- a. Pre-bid meeting attendance sheet.

END OF ADDENDUM

SIGN-IN SHEET

PROJECT: MSU FIELDHOUSE GENERATOR PRE-BID

DATE: 10/9/25 LOCATION: MS4

[illegible]